

Jodi L. Moskowitz  
General Regulatory Counsel  
Operations & Compliance

Law Department  
80 Park Plaza, T5G, Newark, NJ 07102-4194  
tel: 973.430.6409 fax: 973.430.5983  
cell: 973.985.7958  
email: jodi.moskowitz@pseg.com

RECEIVED

09 AUG 31 PM 3:52

PUBLIC SERVICE CORPORATION  
NEWARK, NJ  
**PSEG**  
Services Corporation

August 31, 2009

**VIA HAND DELIVERY**

Ms. Kristi Izzo, Secretary  
New Jersey Board of Public Utilities  
Two Gateway Center – 8<sup>th</sup> Floor  
Newark, New Jersey 07102

**Re: PSEG Solar Hackettstown LLC – Notification Under BPU Affiliate Rules**

Dear Secretary Izzo:

Pursuant to N.J.A.C. 14:4-3.7(d), this letter is submitted by Public Service Electric and Gas Company (“PSE&G”) to notify the BPU of the creation of a new affiliate covered by Chapter 14 of the BPU’s regulations – PSEG Solar Hackettstown LLC, a Delaware limited liability company.

On February 8, 2008, PSE&G notified the Board that PSEG Solar Source LLC had been formed as an indirect wholly-owned subsidiary of PSEG Global LLC. PSEG Solar Source was formed to develop and install solar panels and related equipment for commercial and industrial customers located in New Jersey and other states. Presently, Randall E. Mehrberg is the President of PSEG Solar Source.

On August 27, 2009, PSEG Solar Source formed PSEG Solar Hackettstown as a direct wholly-owned subsidiary to operate solar generation providing approximately 2 megawatts of power for use in the operation of the Mars Snackfood US plant in Hackettstown, New Jersey. On August 27, 2009, PSEG Solar Hackettstown also filed a self-certification with the Federal Energy Regulatory Commission as a Qualified Facility (“QF”) and so notified the Board.<sup>1</sup> Presently, Diana L. Drysdale is the President of PSEG Solar Hackettstown.


As required by N.J.A.C. 14:4-3.7(d), a public posting of the information contained in this letter is being made simultaneously to the website of Public Service Enterprise Group Incorporated (PSEG.com).

<sup>1</sup> See attached PSEG Solar Hackettstown filed FERC Form No. 556.

In addition, PSE&G will update its Affiliate Relations Compliance Plan to reflect the existence of PSEG Solar Hackettstown.

Any questions related to the above-referenced notification should be directed to the undersigned.

Very truly yours,



Jodi L. Moskowitz

Attachment  
JLM/db

cc: Victor Fortkiewicz, BPU  
Jerome May, BPU  
Alice Bator, BPU  
Michael Winka, BPU

Alexander C. Stern  
Assistant General Regulatory Counsel

Law Department  
80 Park Plaza, T5G, Newark, NJ 07102-4194  
tel: 973.430.5754 fax: 973.430.5983  
email: alexander.stern@pseg.com



August 27, 2009

VIA ELECTRONIC MAIL

~~Kimberly D. Bose, Secretary~~  
Nathaniel J. Davis, Sr., Deputy Secretary  
Federal Energy Regulatory Commission  
888 First Street, N.E.  
Washington, DC 20426

Re: PSEG Solar Hackettstown LLC  
Docket No. QF09-

Dear Ms. Bose and Mr. Davis:

Pursuant to Section 292.207(a)(1) of the regulations of the Federal Energy Regulatory Commission ("FERC" or "Commission"), 18 C.F.R. §292.207(a)(1), please find attached for electronic filing FERC Form No. 556 -- Notice of Self-Certification of Qualifying Status for a small power production facility located in Hackettstown, New Jersey. Copies of this filing are also being provided to the local utility company and the state regulatory authority.

If you have any questions regarding this filing, please feel free to contact the undersigned. Thank you for your assistance.

Very truly yours,

*Alexander C. Stern*

Alexander C. Stern

ACS/jb

Cc: Honorable Kristi Izzo, Secretary  
New Jersey Board of Public Utilities  
Two Gateway Center, 8<sup>th</sup> Floor  
Newark, New Jersey 07102

FirstEnergy Corp.  
76 South Main Street  
Akron, Ohio 44308  
Attn: Bruce Rimmel

FERC Form No. 556  
18 C.F.R. § 131.80

CERTIFICATION OF QUALIFYING FACILITY STATUS FOR AN EXISTING OR A  
PROPOSED SMALL POWER PRODUCTION OR COGENERATION FACILITY

INFORMATION ABOUT COMPLIANCE

Compliance with the information collection requirements established by the FERC Form No. 556 is required to obtain and maintain status as a qualifying facility. See 18 C.F.R. § 131.80 and Part 292. An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

SUBMITTING COMMENTS ON PUBLIC REPORTING BURDEN

The estimated burden for completing FERC Form No. 556, including gathering and reporting information, is 4 hours for self-certifications and 38 hours for applications for Commission certification. Send comments regarding this burden estimate or any aspect of this collection of information, including suggestions for reducing this burden, to the following: Michael Miller, Office of the Executive Director (ED-34), Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426; and Desk Officer for FERC, Office of Information and Regulatory Affairs, Office of Management and Budget, Washington, DC 20503 (oira\_submission@omb.eop.gov). Include the Control No. 1902-0075 in any correspondence.

GENERAL INSTRUCTIONS

Complete this form by replacing bold text below with responses to each item, as required.

PART A: GENERAL INFORMATION TO BE SUBMITTED BY ALL APPLICANTS

1a. Full name of applicant: [Note: Applicant is the legal entity submitting this form, not the individual employee making the filing. Generally, the Applicant will be a company, corporation or organization, unless the facility is owned directly by an individual or individuals.]

**PSEG Solar Hackettstown, LLC**

Docket Number assigned to the immediately preceding submittal filed with the Commission in connection with the instant facility, if any:

**None**

Purpose of instant filing (self-certification or self-recertification [18 C.F.R. § 292.207(a)(1)], or application for Commission certification or recertification [18 C.F.R. §§ 292.207(b) and (d)(2)]):

**Self-certification**

## 1b. Full address of applicant:

**PSEG Solar Hackettstown, LLC  
c/o PSEG Global, LLC  
80 Park Plaza T-20  
Newark, New Jersey 07102**

1c. Indicate the owner(s) of the facility (including the percentage of ownership held by any electric utility or electric utility holding company, or by any persons owned by either) and the operator of the facility.

**Upon the completion of construction, PSEG Solar Hackettstown, LLC, a Delaware limited liability company ("Applicant"), will be the 100% owner of the facility. Applicant is a single member entity, wholly owned by PSEG Solar Source, LLC, a Delaware limited liability company.**

**PSEG Solar Hackettstown, LLC is not an "electric utility" as defined in PUHCA 2005 §1262(5) and 18 C.F.R. §366.1 because the facility which is the subject of this application does not exceed 30 MWs and thus qualifies for the QF exemption from PUHCA 2005 set forth in 18 C.F.R. §292.602(b). PSEG Solar Source, LLC is also not an electric utility nor an electric utility holding company.**

**Additionally, state whether or not any of the non-electric utility owners or their upstream owners are engaged in the generation or sale of electric power, or have any ownership or operating interest in any electric facilities other than qualifying facilities.**

**PSEG Solar Hackettstown, LLC and PSEG Solar Source, LLC are indirect subsidiaries of Public Service Enterprise Group, Inc. ("PSEG"), an electric utility holding company within the meaning of PUHCA 2005. PSEG was an exempt public utility holding company under the Public Utility Holding Company Act of 1935. Except for revenues from exempt wholesale generators, foreign utility companies, and qualifying facilities, essentially all of PSEG's public utility company revenues originate in the State of New Jersey.**

**A chart showing the relationship between PSEG Solar Hackettstown, LLC and its upstream owners is attached hereto (Attachment A).**

**None of Applicant's upstream owners are engaged in the generation or sale of electric power.**

In order to facilitate review of the application, the applicant may also provide an ownership chart identifying the upstream ownership of the facility. Such chart should indicate ownership percentages where appropriate.

1d. Signature of authorized individual evidencing accuracy and authenticity of information provided by applicant: [Note: A signature on a filing shall constitute a certificate that (1) the signer has read the filing and knows its contents; (2) the contents are true as stated, to the best knowledge and belief of the signer; and (3) the signer possesses full power and authority to sign the filing. A person submitting a self-certification electronically via eFiling may use typed characters representing their name to show that the person has signed the document. *See* 18 C.F.R. § 385.2005.]

~~Diana L. Drysdale~~

2. Person to whom communications regarding the filed information may be addressed:

Name: **Diana L. Drysdale**

Title: Director Development, Energy Renewables

Telephone number: (973) 430-7497

Mailing address: **PSEG Global LLC  
80 Park Plaza T-20  
Newark, NJ 07102**

3a. Location of facility to be certified:

State: **New Jersey**

County: **Warren**

City or town: **Hackettstown**

Street address (if known): **800 High Street**

3b. Indicate the electric utilities that are contemplated to transact with the qualifying facility (if known) and describe the services those electric utilities are expected to provide:

None

Indicate utilities interconnecting with the facility and/or providing wheeling service [18 C.F.R. §§ 292.303(c) and (d)]:

**Jersey Central Power & Light Company**

Indicate utilities purchasing the useful electric power output [18 C.F.R. §§ 292.101(b)(2), 292.202(g) and 292.303(a)]:

**None – electric power will be purchased and consumed by on-site host.**

Indicate utilities providing supplementary power, backup power, maintenance power, and/or interruptible power service [18 C.F.R. §§ 292.101(b)(3), (b)(8), 292.303(b) and 292.305(b)]:

**Jersey Central Power & Light Company**

4a. Describe the principal components of the facility including boilers, prime movers and electric generators, and explain their operation. Include transmission lines, transformers and switchyard equipment, if included as part of the facility.

**28,680 – First Solar FS-2 75 modules  
8 – SMA 250U inverters  
1 – Cooper 480/4160V generator step-up transformer**

**The facility connects to the host's existing electrical system through a point of common coupling in compliance with the National Electric Code and local electrical codes.**

4b. Indicate the maximum gross and maximum net electric power production capacity of the facility at the point(s) of delivery and show the derivation. [Note: Maximum gross output is the maximum amount of power that the facility is able to produce, measured at the terminals of the generator(s). Maximum net output is maximum gross output minus (1) any auxiliary load for devices that are necessary and integral to the power production process (fans, pumps, etc.), and (2) any losses incurred from the generator(s) to the point of delivery. If any electric power is consumed at the location of the QF (or thermal host) for purposes not related to the power production process, such power should not be subtracted from gross output for purposes of reporting maximum net output here.]

Gross output: **2.151 MW dc**

Net output: **1.818 MW ac**



Derivation (assumptions about losses, auxiliary load or lack thereof, and calculation of gross and net output):

**Losses are limited to the differential between gross output (kW dc) and net output (kW ac). Losses relate to power conditioning equipment losses, wiring losses, transformer losses, losses due to operating conditions (temperature, soiling, shading, etc.) and module product losses.**

4c. Indicate the actual or expected installation and operation dates of the facility, or the actual or expected date of completion of the reported modification to the facility:

**This facility will become operational on or about September 15, 2009.**

4d. Describe the primary energy input (e.g., hydro, coal, oil [18 C.F.R. § 292.202(l)], natural gas [18 C.F.R. § 292.202(k)], solar, geothermal, wind, waste, biomass [18 C.F.R. § 292.202(a)], or other). For a waste energy input that does not fall within one of the categories on the Commission's list of previously approved wastes, demonstrate that such energy input has little or no current commercial value and that it exists in the absence of the qualifying facility industry [18 C.F.R. § 292.202(b)].

**Solar**

5. Provide the average annual hourly energy input in terms of Btu for the following fossil fuel energy inputs, and provide the related percentage of the total average annual hourly energy input to the facility [18 C.F.R. § 292.202(j)]. For any oil or natural gas fuel, use lower heating value [18 C.F.R. § 292.202(m)]:

Natural gas: None

Oil: None

Coal (applicable only to a small power production facility): None

6. Discuss any particular characteristic of the facility which the cogenerator or small power producer believes might bear on its qualifying status.

None

**PART B: DESCRIPTION OF THE SMALL POWER PRODUCTION FACILITY**

Items 7 and 8 only need to be answered by applicants seeking certification as a small power production facility. Applicants for certification as a cogeneration facility may delete Items 7 and 8

from their application, or enter "N/A" at both items.

7. Describe how fossil fuel use will not exceed 25 percent of the total annual energy input limit [18 C.F.R §§ 292.202(j) and 292.204(b)]. Also, describe how the use of fossil fuel will be limited to the following purposes to conform to Federal Power Act section 3(17)(B): ignition, start-up, testing, flame stabilization, control use, and minimal amounts of fuel required to alleviate or prevent unanticipated equipment outages and emergencies directly affecting the public.

No fossil fuel will be used by the facility.

8. If the facility reported herein is not an eligible solar, wind, waste or geothermal facility, and if any other non-eligible facility located within one mile of the instant facility is owned by any of the entities (or their affiliates) reported in Part A at item 1c above and uses the same primary energy input, provide the following information about the other facility for the purpose of demonstrating that the total of the power production capacities of these facilities does not exceed 80 MW [18 C.F.R § 292.204(a)]: [See definition of an "eligible facility" below. Note that an "eligible facility" is a specific type of small power production facility that is eligible for special treatment under the Wind, Waste and Geothermal Power Production Incentives Act of 1990, as subsequently amended in 1991, and should not be confused with facilities that are generally eligible for QF status.]

Facility name, if any (as reported to the Commission):

N/A

Commission Docket Number:

N/A

Name of common owner:

N/A

Common primary energy source used as energy input:

N/A

Power production capacity (MW):

N/A

An eligible solar, wind, waste or geothermal facility, as defined in Section 3(17)(E) of the Federal Power Act, is a small power production facility that produces electric energy solely by the use, as a primary energy input, of solar, wind, waste or geothermal resources, for which either an application for Commission certification of qualifying status [18 C.F.R. § 292.207(b)] or a notice of self-certification of qualifying status [18 C.F.R. § 292.207(a)] was submitted to the Commission not later than December 31, 1994, and for which construction of such facility commences not later than December 31, 1999, or if not, reasonable diligence is exercised toward the completion of such facility, taking into account all factors relevant to construction of the facility.

### PART C: DESCRIPTION OF THE COGENERATION FACILITY

Items 9 through 15 only need to be answered by applicants seeking certification as a cogeneration facility. Applicants for certification as a small power production facility may delete Items 9 through 15 from their application, or enter "N/A" at each item.

9. Describe the cogeneration system [18 C.F.R. §§ 292.202(c) and 292.203(b)], and state whether the facility is a topping-cycle [18 C.F.R. § 292.202(d)] or bottoming-cycle [18 C.F.R. § 292.202(e)] cogeneration facility.

N/A

10. To demonstrate the sequentiality of the cogeneration process [18 C.F.R. § 292.202(s)] and to support compliance with other requirements such as the operating and efficiency standards (Item 11 below), provide a mass and heat balance (cycle) diagram depicting average annual hourly operating conditions. Also, provide:

Using lower heating value [18 C.F.R. § 292.202(m)], all fuel flow inputs in Btu/hr., separately indicating fossil fuel inputs for any supplementary firing in Btu/hr. [18 C.F.R. § 292.202(f)]:

N/A

Average net electric output (kW or MW) [18 C.F.R. § 292.202(g)]:

N/A

Average net mechanical output in horsepower [18 C.F.R. § 292.202(g)]:

N/A

Number of hours of operation used to determine the average annual hourly facility inputs

FERC Form No. 556

and outputs:

N/A

Working fluid (e.g., steam) flow conditions at input and output of prime mover(s) and at delivery to and return from each useful thermal application, including flow rates (lbs./hr.), temperature (deg. F), pressure (psia), and enthalpy (Btu/lb.):

N/A

11. Compute the operating value [applicable to a topping-cycle facility under 18 C.F.R. § 292.205(a)(1)] and the efficiency value [18 C.F.R. §§ 292.205(a)(2) and (b)], based on the information provided in and corresponding to item 10, as follows:

Pt = Average annual hourly useful thermal energy output

Pe = Average annual hourly electrical output

Pm = Average annual hourly mechanical output

Pi = Average annual hourly energy input (natural gas or oil)

Ps = Average annual hourly energy input for supplementary firing (natural gas or oil)

Operating standard = 5% or more

Operating value =  $Pt / (Pt + Pe + Pm)$

N/A

Efficiency standard applicable to natural gas and oil fuel used in a topping-cycle facility:

= 45% or more when operating value is less than 15%, or 42.5% or more when operating value is equal to or greater than 15%.

Efficiency value =  $(Pe + Pm + 0.5Pt) / (Pi + Ps)$

N/A

Efficiency standard applicable to natural gas and oil fuel used for supplementary firing component of a bottoming-cycle facility:

= 45% or more

Efficiency value =  $(Pe + Pm) / Ps$

N/A

FOR TOPPING-CYCLE COGENERATION FACILITIES

Items 12 and 13 only need to be answered by applicants seeking certification as a topping-cycle cogeneration facility. Applicants for certification as a small power production facility or bottoming-cycle cogeneration facility may delete Items 12 and 13 from their application, or enter "N/A" at each item.

12. Identify the entity (i.e., thermal host) which will purchase the useful thermal energy output from the facility [18 C.F.R § 292.202(h)]. Indicate whether the entity uses such output for the purpose of space and water heating, space cooling, and/or process use.

N/A

13. In connection with the requirement that the thermal energy output be useful [18 C.F.R § 292.202(h)]:

For process uses by commercial or industrial host(s), describe each process (or group of similar processes using the same quality of steam) and provide the average annual hourly thermal energy made available to the process, less process return. For a complex system, where the primary steam header at the host-side is divided into various sub-uses, each having different pressure and temperature characteristics, describe the processes associated with each sub-use and provide the average annual hourly thermal energy delivered to each sub-use, less process return from such sub-use. Provide a diagram showing the main steam header and the sub-uses with other relevant information such as the average header pressure (psia), the temperature (deg.F), the enthalpy (Btu/lb.), and the flow (lb./hr.), both in and out of each sub-use. For space and water heating, describe the type of heating involved (e.g., office space heating, domestic water heating) and provide the average annual hourly thermal energy delivered and used for such purpose. For space cooling, describe the type of cooling involved (e.g., office space cooling) and provide the average annual hourly thermal energy used by the chiller.

N/A

FOR BOTTOMING-CYCLE FACILITIES

Item 14 only needs to be answered by applicants seeking certification as a bottoming-cycle cogeneration facility. Applicants for certification as a small power production facility or topping-cycle cogeneration facility may delete Item 14 from their application, or enter "N/A."

14. Provide a description of the commercial or industrial process or other thermal application to which the energy input to the system is first applied and from which the

reject heat is then used for electric power production.

N/A

#### FOR NEW COGENERATION FACILITIES

Response to Item 15 is only required for certain applicants for qualified cogeneration facility status, as described below. Applicants for small power production facilities or for cogeneration facilities not meeting the criteria outlined below may delete Item 15 from their application, or enter "N/A." In addition, per 18 C.F.R. § 292.205(d)(4) all cogeneration facilities 5 MW and smaller are presumed to comply with the requirements of 18 C.F.R. § 292.205(d)(1) and (d)(2), and therefore need not respond to Item 15. For those applicants required to respond to Item 15, *see* 18 C.F.R. § 292.205(d) and Order No. 671 for more information on making the demonstrations required in Item 15.

15. For any cogeneration facility that had not filed a notice of self-certification or an application for Commission certification under 18 C.F.R. § 292.207 prior to February 2, 2006, also show:

(i) The thermal energy output of the cogeneration facility is used in a productive and beneficial manner [18 C.F.R §§ 292.205(d)(1), (d)(4) and (d)(5)]; and

(ii) The electrical, thermal, chemical and mechanical output of the cogeneration facility is used fundamentally for industrial, commercial, residential or institutional purposes and is not intended fundamentally for sale to an electric utility, taking into account technological, efficiency, economic, and variable thermal energy requirements, as well as state laws applicable to sales of electric energy from a qualifying facility to its host facility [18 C.F.R §§ 292.205(d)(2), (d)(3) and (d)(4)].


N/A

FERC Form No. 556

# ATTACHMENT

A

Structure Chart of  
PSEG Solar Hackensack LLC  
August 27, 2009





Document Content(s)

MARS FERC Form 556 8-27-09.PDF.....1-14